



KOMO®  
Product certificate  
K101517/01



Issued 2019-06-15 Replaces -

Valid until Indefinite Dated

Page 1 of 2

SharkBite PEXa EVOH pipes  
**RWC Reliance Worldwide Corporation (Europe) S.L.**

STATEMENT BY KIWA

This product certificate is issued on the base of BRL 5606 "Plastics piping systems of PE-X intended for heating installations: radiator connections" dated 25 October 2016, according to the Kiwa-Regulations for Certification.

The quality system and product characteristics in association with SharkBite PEXa EVOH pipes are assessed periodically.

On this basis Kiwa declares that a justified confidence exists, that the delivered by the certificate holder at delivery fulfil:

- the technical specification laid down in this product certificate,
  - the product requirements as laid down in this product certificate and in the BRL.
- provided that SharkBite PEXa EVOH pipes have been marked with the KOMO®-mark in a manner as indicated in this product certificate;

Ronald Karel  
Kiwa

*This product certificate is only valid in combination with a KOMO certified plastics piping system.*

Kiwa Nederland B.V.  
Sir Winston Churchillaan 273  
Postbus 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
Fax +31 88 998 44 20  
info@kiwa.nl  
www.kiwa.nl

Holder of Certificate  
RWC Reliance Worldwide  
Corporation (Europe) S.L.  
Autovía A-92 km 209  
18370 MORALEDA DE ZAFAYONA,  
GRANADA  
Spain  
Tel. +34 (0)958 497 000  
Fax +34 (0)958 443 704  
info@rwc.com  
www.rwc.com



Evaluated is:  
quality system  
product  
Periodic inspection

## SharkBite PEXa EVOH pipes

---

### TECHNICAL SPECIFICATION

#### Subject

SharkBite PEXa EVOH pipes

#### Product characteristics

The product complies to BRL 5606 Plastics piping systems of PE-X intended for heating installations: radiator connections.

#### Specification

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside diameter (mm)	Wall thickness (mm)
16	2,2
20	2,8
25	3,5
32	4,4

Colour: inside: natural/ outside: silver

#### Marking

The products shall be marked with the KOMO® mark.

#### Pipes

The minimum required marking on the pipes shall be:

- KOMO (or KOMO® word mark) + class 4 and 5/ 6 bar;
- material identification: PE-Xa;
- the build up of the pipe; PE-Xa//EVOH;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clear, durable and indelible at intervals of not more than 2 meters.

#### Logistics

Production and assembly of the system is laid down in the annex of the certification agreement.

### APPLICATION AND USE

The products are intended to be used for piping systems for heating installations: radiator connections and floor heating systems with a lifetime of 50 years at an operating temperature profile according to class 4/ 5 of ISO 10508 and an allowable working pressure of maximum 6 bar.

### RECOMMENDATION FOR THE CUSTOMER

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

if you should reject a delivery on the basis of the above, please contact:

- RWC Reliance Worldwide Corporation (Europe) S.L.

and, if necessary:

- Kiwa Nederland B.V.

For the proper storage, transport and processing consult the instructions of the certificate holder.

